



# CITY OF HUNTINGTON BEACH

## Finance Department Purchasing Division

Bob Wingenroth  
Director of Finance

May 6, 2010

This is addendum #2A for our Request for Quotation 10-0518 Murdy Community Center Roof Replacement. Please note changes from Section 07520 Modified Bituminous Membrane Roofing – Hot Applied section: The following are correct:

1. Section 07520  
Part 1 – General  
1.2 Summary  
1, 3. Please replace “Prime deck with 1 gallon per square of Garla Prime asphalt primer”

With

“Loose lay rosin paper and nail a Type II Base Sheet according to ASCE 7-5 calculations provided with bid to comply with International Building Code (IBC)”

2. This project requires the payment of **“federal” prevailing wages.**
3. The City will be utilizing a labor compliance consultant to monitor prevailing wage compliance; prior to starting the project, the consultant will meet with the contractor to review the compliance process.

If you have any future questions, please feel free to email me.

Regards,

Marilyn Goldstein  
Buyer